

ORDINANCE NO. 2012- 3573


AN ORDINANCE AUTHORIZING THE APPROVAL AND ISSUANCE OF A WARRANT FOR PAYMENT OF \$927.84 TO OHIO CAT AND DECLARING AN EMERGENCY.

WHEREAS, Ohio CAT submitted an invoice to the City of Fremont Police Department for backup generator repairs totaling \$927.84, and prior certification of the fiscal officer was not obtained in violation of Ohio Revised Code section 5705.41(D), therefore

BE IT ORDAINED BY THE COUNCIL OF THE CITY OF FREMONT, STATE OF OHIO:

SECTION 1. City Council hereby authorizes the approval and issuance of a warrant in payment of the amount of \$927.84 to Ohio CAT; and


SECTION 2. This Ordinance, provided it receives not less than five (5) yea votes, is hereby declared to be an emergency measure for the health, safety, and welfare of the citizens of the City of Fremont, said emergency being the need of the aforementioned bill to be paid in a timely manner.


James G. Weaver
President of Council

PASSED: 2-16-12
Effective date: 2-16-12


YEAS: 7 NAYS: 0


Elaine J. Cley
City Council Clerk


James H. Ellis, Mayor

ORDI718

Approved as to form:

A handwritten signature in cursive script, appearing to read 'J F Melle', written over a horizontal line.

James F. Melle, Director of Law
City of Fremont, Ohio

Customer #: 1125880

Amount Due: \$927.84

Enroll now to receive your future invoices electronically! Go to <http://viewpdf.connectplusonline.com> and enter your temporary:

Username: DN60406948

Password: B9ca95c467

Invoice Number	Invoice Date	Customer No.	Customer Purchase Order Number	Store	PSO/WO No.	Page
W0230128000	12/18/11	1125880	CHIEF WIERSMA	23	TP32801	1
Make	Model	Serial Number	Equipment Number	Meter Reading	Doc. Date	
AA	D100	0D4B01537	POLICED	12.0	12/05/11	
Quantity	Item	*NR	Description	Unit Price	Extension	

TROUBLESHOOT GENERATOR SET

CUSTOMER COMPLAINT: UNIT SHUT DOWN TRAVELED TO CUSTOMER SITE. FOUND ENGINE SHUT DOWN ON LOW COOLANT LEVEL. COOLANT LEVEL CHECKED, OK. FOUND THE LEVEL SENSOR BAD. ORDERED NEW SENSOR. RETURNED TO SITE.

SHUT DOWN POWER TO JACKET WATER HEATER AND LOCKED OUT UNIT.

DRAINED COOLING SYSTEM.

REMOVED EXISTING SENSOR AND REPLACED WITH NEW. REFILLED COOLING SYSTEM AND TURNED ON POWER TO HEATER. CHECKED HEATER FOR PROPER OPERATION. ALL OK.

STARTED UNIT TO TEST AND CHECK FOR LEAKS.

UNIT READY FOR OPERATION.

6	8T-8730		CONNECTOR	N	1.25	7.50
2	155-2260		PLUG KIT-CON	N	3.84	7.68
2	362-2913		SENSOR AS-LE	N	68.98	137.96
			TOTAL PARTS	SEG. 01		153.14
			RT FIELD LABOR			454.50
			TOTAL LABOR	SEG. 01		454.50
1.0	0		PTS FUEL SURCHRG			0.50

20120159 RECEIVED JAN 10 2012 FREMONT POLICE

gfw

PAY THIS AMOUNT	\$927.84
CREDIT AMOUNT	

CAT INVOICE

PAYMENT TERMS: Net 30 Days from invoice date. A monthly Finance Charge up to 2% (24% APR) will be added on all past due amounts. Title to goods remains with seller until full payment is received. Returned parts must be accompanied by invoice or Packing list and are subject to a restocking fee. Parts designated with an asterisk (*) are not returnable.

Shipped To: 1125880

#20120159
101-320-754

RECEIVED

JAN 13 2012

CITY OF FREMONT, OHIO